

CERTIFICATE OF COMPLIANCE

Certificate Number E183151
Report Reference E183151-20100811
Issue Date 2020-FEBRUARY-03

Issued to: PROSOFT TECHNOLOGY INC
9201 CAMINO MEDIA, SUITE 200
BAKERSFIELD CA 93311

**This certificate confirms that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

Refer to Addednum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA-12.12.01-2015/ CAN/CSA C22.2 No. 213-15 -
Nonincendive Electrical Equipment for Use in Class I and II,
Division 2 and Class III, Divisions 1 and 2 Hazardous
(Classified) Locations.

UL 508 - Industrial Control Equipment.

CSA C22.2 No - 142-M1987, Process Control Equipment.


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E183151
Report Reference E183151-20100811
Issue Date 2020-FEBRUARY-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL – Programmable Logic Controllers for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Communication module Models:


MVI56E; followed by –GSC, -MCM, -MCMR, MCMXT, -MNET, -MNETXT, MNETC, MNETCXT, MNETCR, MNETR, FLN, SIE, DNPNET, 61850S, GSCXT, LDM, AFC or GEC.

MVI56; followed by –HART or –PDPMV1.

MVI46; followed by –HART or –PDPMV1.

ILX56-MM.

Devices may be marked with suffix “-CC” indicating conformal coating.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

